

↓冬は濃度が高い

	Date	Time	オゾン濃度
1	01/29	09:10	0.72
2	01/30	09:04	0.74
3	02/01	09:10	0.75
4	02/01	11:19	0.70
5	02/02	09:21	0.74
6	02/05	09:12	0.74
7	02/08	11:18	0.73
8	02/09	09:04	0.73
9	02/09	09:22	0.73
10	02/10	09:08	0.73
11	02/13	09:04	0.73

	Date	Time	オゾン濃度
1	03/15	09:02	0.73
2	03/19	09:12	0.71
3	03/22	09:08	0.73
4	03/23	09:02	0.72
5	03/25	09:17	0.73
6	03/28	09:04	0.71
7	03/29	11:30	0.71
8	03/29	09:05	0.71
9	03/30	09:08	0.71
10	04/04	09:12	0.71
11	04/04	11:37	0.69

↓夏は濃度が低い

	Date	Time	オゾン濃度
1	06/27	09:02	0.68
2	06/27	11:22	0.65
3	06/28	09:07	0.69
4	06/28	10:42	0.65
5	06/29	09:07	0.69
6	07/01	09:07	0.67
7	07/02	09:06	0.68
8	07/04	09:07	0.66
9	07/05	09:05	0.68
10	07/05	10:25	0.65
11	07/06	09:04	0.69

	Date	Time	オゾン濃度
1	07/05	10:25	0.65
2	07/06	09:04	0.69
3	07/08	09:07	0.68
4	07/08	12:15	0.66
5	07/08	12:32	0.64
6	07/11	09:06	0.68
7	07/11	11:37	0.66
8	07/12	09:11	0.66
9	07/12	11:01	0.64
10	07/12	15:47	0.67
11			

異常発生時

	Date	Time	オゾン濃度
1	07/12	15:47	0.67
2	07/12	16:04	0.67
3	07/12	16:37	0.67
4	07/12	16:49	0.68
5	07/12	17:04	0.67
6	07/12	17:17	0.67
7			
8			
9			
10			
11			

→ 給水側 活性炭フィルター設置時 濃度

→ 給水フィルターなど 濃度